



## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 21.02.2024

It is certified that an inspection team headed by Mr. Tasso. Ram

(Name of Officers with designation) from PHE & W Division, ZIRO, PHED

inspected the RES LOVE DALE RESIDENTIAL SCHOOL

(Name & Address of the school) on 21.02.2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. Z/PHE/T/2023-24/03 dated 21-2-2024

of ZIRO (PHED Lab) certified that the


Love Dale Residential School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 1(one) year.

Signature with Seal: 

Name : Assistant Engineer

Designation : Public Health Engineering

Name & Address of the Office/ Department : Office, PHED, ZIRO

To  
LOVE DALE RESIDENTIAL SCHOOL  
S/IBR, HAPOLI, ZIRO, A.P  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Principal  
LOVE DALE RESIDENTIAL SCHOOL  
Hapoli, Ziro, Arunachal Pradesh

  
Chairperson  
Love Dale Welfare Society and  
Rehabilitation Council, Ziro  
Dist. L/ Subansiri (A.P)

GOVERNMENT OF ARUNACHAL PRADESH

OFFICE OF THE EXECUTIVE ENGINEER :: PHE & WS DIVISION ZIRO

X/OHE/T/2023-24/03

Dated: 21st Feb '24

WATER QUALITY ANALYSIS REPORT OF LOVE DALE SCHOOL HAPOLI

The Water Quality Test performed as per the availability of equipments, chemicals etc in our Laboratory, the water sample of Love Dale School Hapoli, are found to be potable and free from chemical contamination. All parameter tested are very much under the desirable limits. The water analysis report are as follow:

Sl.No	PARAMETER/ UNIT	OBSERVED VALUE	PERMISSIBLE LIMIT	REMARKS
1	pH value	6.8	6.5-8.5	The water sample of Love Dale School is free from chemical Contamination.
2	Turbidity (NTU)	3	5	
3	Hardness (ppm)	95	600	
4	Iron	0.02	0.3 ( 1 ppm max.)	
5	Fluoride	0.0	1.5	
6	Sulphate	0.0	200	
7	Manganese	0.0	0.1	
8	Ammonia	0.0	0.5	
9	Bacterial Test	nill		

This is for your kind information and necessary action please.

Lab. Technician  
PHE & WS Division  
Ziro

Copy to:

1. Principal Love Dale School Hapoli
2. Office copy

Principal  
LOVE DALE RESIDENTIAL SCHOOL  
Hapoli, Ziro, Arunachal Pradesh

Chairperson  
Love Dale Welfare Society:  
Rehabilitation Council, Ziro  
Dist. L/Subansiri (A.P.)